

**APPENDIX F – EXAMPLES OF TEMPORARY SIGNS, CAUTION NOTICES, DISPLAY OF INFORMATION AND PERMANENT SAFETY SIGNS**

 <p>Standard electrical warning sign – for use with – Live Bus-bar, Switchgear, live electrical equipment, warning of death, uninterruptible power supplies, working near live electrical equipment etc.</p>	 <p>Example of electrical warning sign with mandatory instructions for example for use with multiple supplies, remotely/automatically controlled generating sets, main Intake Switch Sign, switch off electrical equipment before working etc.</p>
 <p>Example of an electrical Prohibition Notice, primarily used as a Caution Notice</p>	 <p>Electrical warning sign with mandatory action sign for locking HV enclosures, isolation prior to working for LV and HV equipment (Caution Notice), etc.</p>
 <p>Switch Room 14</p> <p><b>Danger</b> 400 Volts</p> <p>Authorised personnel only</p> <p>Keep clear</p> <p>Keep locked</p> <p>This area is under the control of Estates Operations</p> <p>In case of emergency or for general access, please contact: Estates Help Desk on extension 101, or report to Estates Operations.</p> <p>A Permit to Work may be required.</p> <p><small>Rutherford Technology Partnership Rutherford Appleton Laboratory</small></p>	 <p>First Aid for High Voltage Electrical Shock Sign</p>



**CAUTION**  
Persons  
working on  
equipment



**DO NOT  
TOUCH**

Example of an electrical Prohibition Notice, primarily used as a Caution Notice.



Electrical Warning Sign used on electrical equipment such as switchgear and HV Enclosures.